

Message

From: Landis, Victor [vlandis@pa.gov]
Sent: 9/18/2019 3:34:18 PM
To: Maslowski, Steven [Maslowski.Steven@epa.gov]
Subject: RE: [External] CRW Front Street Repairs.

According to CRWs Annual Report, they submitted on 2/25/15. I will check my files too.

Victor H. Landis | Environmental Group Manager
Department of Environmental Protection
Southcentral Regional Office
909 Elmerton Avenue | Harrisburg, PA 17110
Phone: 717.705.4772 | Fax: 717.705.4760
24-Hour Emergency Response: 866-825-0208
www.depweb.state.pa.us

24-hour toll free Emergency Response number for SCRO: 1-800-541-2050.

From: Maslowski, Steven <Maslowski.Steven@epa.gov>
Sent: Monday, September 16, 2019 11:17 AM
To: Landis, Victor <vlandis@pa.gov>
Cc: Dock, Heather <hdock@pa.gov>
Subject: [External] CRW Front Street Repairs.

ATTENTION: This email message is from an external sender. Do not open links or attachments from unknown sources. To report suspicious email, forward the message as an attachment to CWOPA_SPAM@pa.gov.

Hi Victor,

Do you recall CRW submitting remedial work for the Front Street Interceptor by the PCD deadline of March 1, 2015? I have to go back into my files to find its submittal. Because this work was supposed to be completed by July 1, 2019, and I did not get anything in the mail about meeting this task. I know they are doing construction on the Front Street now. We may have another stip to add to the list. Enclosed is the CD requirement.

31. CRW shall complete the following projects within the timeframes set forth below:

a. High Priority Combined Sewer Interceptor Improvements. CRW shall perform a comprehensive assessment of the structural integrity of the Front Street Interceptor by October 31, 2014. Based on the findings of the assessment, CRW shall identify all priority remedial work in the Front Street Interceptor and develop a construction schedule to submit to Plaintiffs for review and approval pursuant to Section VI (Review and Approval of Deliverables) by March 1, 2015. All priority remedial work under the construction schedule proposed is to be completed by July 1, 2019. For the purposes of this Paragraph, priority remedial work shall include, but not be limited to, all Front Street Interceptor segments that, based on an engineering assessment of internal inspection data, receive a pipe segment index score of "5" or "4" using the National Association of Sewer Service Companies ("NASSCO") Pipeline Assessment Certification Program and Manhole Assessment Certification Program. Progress on all priority remedial work conducted pursuant to this Paragraph shall be reported in the Semi-Annual Reports pursuant to Section VII (Reporting Requirements).

Steve Maslowski

NPDES Section
EPA Region III
215-814-2371